

## ADDENDUM #1

May 16, 2014

### **West Manchester / Main Street Improvements, High St. Waterline Upgrades & Park Renovations** Village of West Manchester, Ohio

The following additions or modifications to the specifications for the Main Street Improvements, High St. Waterline Upgrades & Park Renovations project shall become a part thereof. Where these items differ from the original specifications, THIS shall govern.

1. **General Notes Sheet, Page 2 of Plans**

See attached General Notes Sheet (1 Reduced Page) reflecting “**Trench Repair Procedures**” **note changes in bold font**. The note was changed to provide clarity on daily backfill requirements.

2. **Contractor’s Bid Sheet & Waterline Notes, Details & General Summary Sheet, Page 3 of Plans**

See attached revised Contractor’s Bid Sheet (6 Pages) and Waterline Notes, Details, & General Summary Sheet (1 Reduced Page) reflecting changes to **item numbers, quantities, addition and removal of items shown in bold font and in revision clouds**.

3. **Typical Sections & Details Sheet, Page 4 of Plans**

See attached Typical Sections & Details Sheet (1 Reduced Page) reflecting the removal of the “**Survey Monument Detail**” and changes to three concrete call outs from Class C Concrete to **Class QC 1 Concrete (shown in revision clouds)**. Any other references to Class C Concrete throughout the plans shall be changed to Class QC 1 or Class QC Misc.

4. **Typical Sections & Details Sheet, Page 5 of Plans**

See attached Typical Sections & Details Sheet (1 Reduced Page) reflecting the changes to three granular backfill call outs from ODOT Item Number 603 to **ODOT Item Number 611 (shown in revision clouds)**. Any other references to ODOT Item Number 603 throughout the plans shall be changed to ODOT Item Number 611. Please note the “Item 611” note on the General Notes sheet.

5. **Plan & Profile Sta. 112+00 to 118+00 Main Street Sheet, Page 10 of Plans**

See attached Plan & Profile Sta. 112+00 to 118+00 Main Street Sheet (1 Reduced Page) reflecting the **removal of three Construction Note 27 “Connect to Existing Waterline” (shown in revision clouds)**. The work required to switch over the three service connections are covered by other bid items. Also, **Construction Note 17 and 24 were revised (shown in revision clouds)**. Construction Note 17 was revised to include the installation of storm water curb openings (Neenah R-3262-3 with 4” ID Outlet) as shown on the bid form. Construction Note 24 was revised to clarify the Contractor is to install new water meter/valve. The Village is to supply material only.

6. **Federal Davis Bacon Wage Rates**

The Federal Davis Bacon Wage Decision was revised on May 9, 2014. All bidders are required to use the revised Davis Bacon Wage Decision for this project, see attached.

Please acknowledge receipt of Addendum #1 by signing in the space provided below and e-mail back a copy of the signed acknowledgement to the Board of Preble County Commissioners Office, attention Kim Keller, [kkeller@prebco.org](mailto:kkeller@prebco.org), or by faxing a copy to (937) 456-8114, attention Kim Keller.

---

I have received Addendum #1 for the Village of West Manchester – West Manchester / Main Street Improvements, High St. Waterline Upgrades & Park Renovations project.

---

Signature

---

Company Name

---

Date