

ADDENDUM #1

July 2, 2013

W.W.T.P. EMERGENCY GENERATOR PROJECT

Village of West Manchester, Preble County, Ohio

The following additions or modifications to the specifications for the WWTP Emergency Generator project shall become a part thereof. Where these items differ from the original specifications, **THIS** shall govern.

1. **FEDERAL DAVIS BACON WAGE RATES**

The Federal Davis Bacon Wage Decision was revised on June 28, 2013. All bidders are required to use the revised Davis Bacon Wage Decision for this project. See attached revised Federal Davis Bacon Wage Decision.

2. **TIME OF COMPLETION & LIQUIDATED DAMAGES**

Modify the Time of Completion from 60 consecutive calendar days thereafter to 120 consecutive calendar days thereafter and modify the Liquidated Damages from the sum of \$300 for each consecutive day thereafter to \$100.00 for each consecutive day thereafter, in the "Instructions Bidders" section, as well as any other section throughout the contract documents and specifications.

Revisions should read as follows:

"The Bidder must agree to commence work on or before a date to be specified in a written "Notice to Proceed" of the Board and to fully complete the project within 120 consecutive calendar days thereafter. The Bidder must agree also to pay as liquidated damages, the sum of \$100.00 for each consecutive calendar day thereafter as hereinafter provided in the General Conditions."

3. **GENERAL CONTRACTOR / ELECTRICAL WORK CLARIFICATION**

The General Contractor is responsible for providing concrete expansion bolts to anchor the equipment installed on the three (3) concrete pads. Anchorage shall conform to the manufacturer's recommendation.

4. **REVISE SECTION GS 3.1, PARAGRAPH B.4**

Delete requirement to comply with NFPA 110 communication capability.

Please acknowledge receipt of Addendum #1 by signing in the space provided below and e-mail back a copy of the signed acknowledgement to the Board of Preble County Commissioners Office, attention Kim Keller, kkeller@prebco.org, or by faxing a copy to (937) 456-8114, attention Kim Keller.

I have received Addendum #1 for the Village of West Manchester – WWTP Emergency Generator project.

Signature

Company Name

Date